

## Heating, ventilation and sanitation systems: Project planning conditions for electrical operations rooms

Information within brackets ([...]) in this document refers to local regulations.

### Scope

SSG 3703E provide guidelines for planning, projecting and execution of air conditioning installations and cooling systems for electrical operations rooms where high purity is required for protection against corrosive gases.

Electrical-technical components' ever increasing spread within new areas of application has meant that such equipment, to an increasing degree, is exposed in environments where the risk for atmospheric corrosion is obvious.

In many plants the untreated air frequently comprises of dust and corrosive gasses. In addition there are varying temperatures and humidity. It is therefore of great importance that the values of these parameters are kept within established limits.

When designing air treatment installations in accordance with these instructions, the physical lifecycle of the concerned sensitive electrical-technical equipment ought to be optimal.

### Contents

<b>1</b>	<b>Electrical operations rooms</b>	<b>2</b>
1.1	Introduction	2
1.2	General principles	2
1.3	Electrical safety	2
1.4	General project instructions	3
1.4.1	Environmental analysis, choice of air treatment level	3
1.4.2	Planning	3
1.4.3	Material and function selection	4
1.4.4	Projecting basis	5
1.5	Fire safety	5
1.6	Classification	6
1.7	Documentation	6
1.8	Testing and final inspection	7
1.9	Operations and maintenance	7
1.9.1	General	7
1.9.2	Instructions	7
1.10	Guidelines for dimensioning of cooling needs due to effect losses in electrical and operations rooms	9
1.10.1	Typical examples of different effect losses of electrical-technical equipment according to suppliers	9
<b>2</b>	<b>Examples of general project instructions</b>	<b>9</b>
2.1	System solutions	9
2.1.1	Environmental requirements	10
2.1.2	Dimensioning and performance instructions	11
2.2	Switchgear	17
<b>3</b>	<b>References</b>	<b>18</b>