

## Heating, ventilation and sanitation systems: Project planning conditions for personnel areas

### Scope

SSG 3705E provides project planning conditions for different types of personnel areas. In most cases, it refers to the Swedish building standard, which then includes the requirements in the National Board of Housing, Building and Planning's building regulations, BFS 2011: 6, including amending statutes, and [AMA VVS & Kyla 19] from Svensk Byggtjänst.

Where required, SSG 3705E addresses issues that need special consideration in certain areas.

### Contents

<b>1 Room types</b>	<b>3</b>
1.1 Personnel areas	3
1.1.1 Sauna	3
1.1.2 Shower	3
1.1.3 Conference room	3
1.1.4 Offices	3
1.1.5 Kitchen and pantry	3
1.1.6 Omklädningsrum	3
1.1.7 Cleaning	3
1.1.8 Rest room	3
1.1.9 WC	3
1.2 Laboratory	4
1.2.1 Water supply	4
1.2.2 Sanitation	4
1.2.3 Cooling systems	4
1.2.4 Heating systems	4
1.2.5 Ventilation systems	4
1.2.6 Control and surveillance/monitoring systems	4
1.2.7 Other	4
<b>2 Electrical-technical areas</b>	<b>5</b>
2.1 Battery room/UPS	5
2.2 Lighting, low and high tension switchgear	5
2.3 Computer room	5
2.4 Frequency transformer room	5
2.5 Cable basement	5
2.6 Cross-connection room	5
2.7 Control rooms	5
2.8 Switchgear	5
2.9 Systems room	5
2.10 Testing room – electrical	5
2.11 Transformers	5
2.12 Battery rooms	5
2.13 Gas protection room – class A	6
2.13.1 Water supply	6
2.13.2 Sanitation	6
2.13.3 Cooling systems	6
2.13.4 Heating systems	6
2.13.5 Ventilation systems	6
2.13.6 Control and surveillance/monitoring systems	6
2.13.7 Other	6