

Heating, ventilation and sanitation systems: Component numbering

Scope

SSG 3709E includes recommendations for naming and numbering components in heating, ventilation and sanitation systems. Adaptation should be made to each facility's own standard.

Contents

1 General	1
2 Department	1
3 Object type	1
4 Serial number/location number	1
5 Component designation	2
5.1 Component designation – example	3
6 Index	8
7 References	8

1 General

Example of address construction: User address

Permitted letters: A–Ö

Permitted numbers: 0–9

Table 1 Example:

	808	-	VL	802	-	GT301	-	X
Department								
Object type								
Serial number/location number								
Component designation								
Index								

2 Department

The installation's system for numbering different departments must be used unless otherwise agreed.

3 Object type

Object type must be specified, according to [SSG 5275E](#) – *Function based identification system for processes and plants* or corresponding.

4 Serial number/ location number

Serial number or location number must be used.