

## Heating, ventilation and sanitation systems: Component numbering

### Scope

SSG 3709E includes recommendations for naming and numbering components in heating, ventilation and sanitation systems. Adaptation should be made to each facility's own standard.

### Contents

<b>1 General</b> .....	1
<b>2 Department</b> .....	1
<b>3 Object type</b> .....	1
<b>4 Serial number/location number</b> .....	1
<b>5 Component designation</b> .....	2
5.1 Component designation – example .....	3
<b>6 Index</b> .....	8
<b>7 References</b> .....	8

### 1 General

Example of address construction: User address

Permitted letters: A–Ö

Permitted numbers: 0–9

**Table 1** Example:

	808	-	VL	802	-	GT301	-	X
Department								
Object type								
Serial number/location number								
Component designation								
Index								

### 2 Department

The installation's system for numbering different departments must be used unless otherwise agreed.

### 3 Object type

Object type must be specified, according to [SSG 5275E](#) – *Function based identification system for processes and plants* or corresponding.

### 4 Serial number/ location number

Serial number or location number must be used.