Förhandsgranskning / Preview

STANDARD SOLUTIONS GROUP

SSG 3709E

Date	Edition	Designation	Page
2022-06-29	1	TKM	1 (8)

Heating, ventilation and sanitation systems: Component numbering

Scope

SSG 3709E includes recommendations for naming and numbering components in heating, ventilation and sanitation systems. Adaptation should be made to each facility's own standard.

Contents

1 General . . . 1
2 Department . . . 1
3 Object type . . . 1
4 Serial number/location number . . . 1
5 Component designation . . . 2
5.1 Component designation – example . . . 3
6 Index . . . 8
7 References . . . 8

1 General

Example of address construction: User address

Permitted letters: A–Ö

Permitted numbers: 0–9

Table 1 Example:

	808	-	VL	802	-	GT301	-	X
Department								
Object type								
Serial number/location number								
Component designation								
Index								

2 Department

The installation's system for numbering different departments must be used unless otherwise agreed.

3 Object type

Object type must be specified, according to SSG 5275E – *Function based identification system for processes and plants* or corresponding.

4 Serial number/ location number

Serial number or location number must be used.

SSG Standards are covered by copyright and may not be reproduced without special permission.
www.ssg.se