

## Switch gear for A.C. voltages above 1 kV and up to and including 24 kV

### Guidance information

*[Information within brackets in this document refers to national standards]*

This version differs from the previous one in that a general review has been carried out, there has been adaptation to current regulations and standards and a question checklist of frequently asked questions, relating to inquiries, purchasing and suchlike, has been transferred from the main document to the new appendix.

**In this version the question checklist (appendix 1--3) has also been produced in an interactive version to allow digital processing.**

The list does not claim to be absolutely comprehensive or exhaustive, however, but represents a form of support in association with inquiries, purchasing etc. of switchgear equipment.

General requirements regarding testing, inspection, control, documentation and training are found in SSG-Delivery contract and General Regulations 90-12.

Regarding low voltage switchgear and controlgear for max 1000V, reference is to be made to SSG 4151E.

### Contents

#### 1 Introduction

#### 2 Regulations, standards, definitions, system arrangement

##### 2.1 Regulations and standards

##### 2.2 Directives

###### 2.2.1 CE-marking

###### 2.2.2 The EMC Directive (2004/108/EC)

#### 3 Definitions

Appendix No. 1: Scope of delivery for switch and controlgear

Appendix No. 2: Electrotechnical data

Appendix No. 3: Construction

Appendix No. 4: Example switchgear for voltage 1 kV up to 24 kV

Appendix No. 5: Verifications(examination, testing, inspection and control)

Appendix No. 6: Documentation standard

Appendix No 7: Training

Appendix No. 8: Principle for DC-circuit and designations in high-voltage switchgear and switchgear for voltage max 1000 V