Förhandsgranskning / Preview

SSG

SSG 4155E

Phase compensation

General

[Information within brackets in this document refers to local regulations]

These recommendations concern fundamental concepts related to reactive power and phase compensation (also frequently known as power factor correction), harmonics and filters, and a number of technical and economic aspects of phase compensation by means of power capacitors.

Contents

1 Introduction

2 References

3 Consumption and generation of reactive power
3.1 Rotary phase compensators
3.1.1 Synchronous generators
3.1.2 Synchronous compensators
3.1.3 Synchronous motors
3.2 Capacitors

4 Phase compensation

5 Determination of capacitor rating
5.1 Exceeded reactive power consumption
5.2 Phase compensation is economically justifiable
5.3 Connection to a fully loaded sub-distribution
5.4 Phase compensation at the project design stage of a new plant
5.5 Capacitors for voltage regulation
5.6 Starting of large machines

6 Compensation methods
6.1 Synchronous motors
6.2 Capacitor banks
6.2.1 Central compensation
6.2.2 Group compensation
6.2.3 Direct compensation

7 Automatically controlled capacitor banks

8 Direct-compensated equipment
8.1 Induction motors
8.2 Distribution transformers0
8.3 Static converterinstallations1

9 Harmonic and resonance problems 2

10 Switching current surges 3

11 Risks/Problems 5
11.1 Intermediate voltage
11.1.1 Switching currents5
11.1.2 Voltage rise, capacitors
11.1.3 Voltage rise, transformer
11.1.4 Switching order, filters
11.1.5 Disturbances
11.1.6 Installation - losses
11.1.7 Resonance - discharge
11.2 Low voltage
11.2.1 Switching currents

Not to be reprinted without permission