

## Distribution- and Lighting transformers, 3-phase, 50 Hz

### General

These recommendations deals with distribution transformers for transforming of motor- and/or lighting power from distribution to consumption voltage.

Transformers to these recommendations shall comply with the EN-and IEC-standards specified with the additions and extracts specified in Section 2 below.

To facilitate the use of the standard, a note is entered in the right-hand margin of Section 2. Requirements to denote each addition to, extract from or deviation from the standard(s) in question. Those parts of Section 2 which are not annotated are essentially in agreement with the standards.

### Changes to the previous edition

This version differs from the previous one in that it has been supplemented with Temperature, Environmental and Climate Class

### Contents

#### 1 Designations

#### 2 Requirements

##### 2.1 General

##### 2.1.1 References

##### 2.1.2 Tap changing device

##### 2.1.3 Insulation level

##### 2.1.4 Connection elements

##### 2.1.5 Rating plates

##### 2.2 Method of cooling and degree of protection

##### 2.3 Rated power

##### 2.4 Rated voltage

##### 2.5 Vector group, distribution transformer

##### 2.6 Supplementary information

##### 2.6.1 Guarantee data; penalty and bonus clause

##### 2.6.2 Terminal connections

##### 2.6.3 Noise suppression

##### 2.6.4 Accessories

##### 2.6.5 Surface treatment

##### 2.6.6 Temperature Class

##### 2.6.7 Environmental Class

##### 2.6.8 Climate Class

#### 3 Relevant standards -Transformers

#### Appendix 1, Specification sheet DS.....