

Installation principles – analysis equipment (A)

Scope

SSG 5402E includes installation principles for analysis equipment installation. Target groups are purchasers and suppliers. The purchaser specifies the desired delivery in the editable word documents that accompany the standard and suppliers perform installation according to the specification.

Changes since the previous edition

This edition differs from the previous one as follows:

- The information in the respective principles has been updated to be relevant and has been harmonised with SSG pipe standards.
- References have been reviewed and updated.
- SS steel has been replaced with current references to materials.
- The installation principles can now be filled out and edited digitally. When editing existing text, the text turns red on grey to indicate that the content deviates from standard.
- In the respective principle, information concerning the material and dimension has been removed when a material code is specified. The information is then available in SSG 5415E — *Instrument installation — list of materials*. This is to reduce the risk of error, as the information is then only in one location.
- A section on designation has been added.
- In principle A4, detail 1, pH meter has been replaced with pH electrode.
- The standard has been updated according to the current template for SSG standards.



Contents

1	Related documents.....	2
2	Installation principles according to SSG.....	2
3	Designation	3
4	References.....	4
	SSG 5402E-A01: pH measurement with throughflow	
	SSG 5402E-A03: pH measurement with immersion in pool/channel with mounting stand	
	SSG 5402E-A04: pH measurement – In-line	
	SSG 5402E-A05: Conductivity measurement without cooler	
	SSG 5402E-A06: Conductivity measurement with cooler	
	SSG 5402E-A07: Conductivity meter — in-line	
	SSG 5402E-A08: O ₂ -analysis	
	SSG 5402E-A09: Smoke density measurement	
	SSG 5402E-A10: Concentration measurement with rotating sensor elements	
	SSG 5402E-A11: Concentration measurement of “shark fin” model	
	SSG 5402E-A12: Viscosity measurement	
	SSG 5402E-A13: Density measurement with radioactive source	
	SSG 5402E-A14: Density measurement with capillary reference	
	SSG 5402E-A15: Density measurement with refractometer	
	SSG 5402E-A16: Concentration measurement with semi-rotating fin	
	SSG 5402E-A17: Concentration measurement with optical measurement method	
	SSG 5402E-A19: Freeness value measurement in-line	
	SSG 5402E-A20: Freeness value measurement off-line	
	SSG 5402E-A21: Continuous concentration and turbidity measurement	
	SSG 5402E-A22: pH measurement with throughflow (2 wire)	
	SSG 5402E-A23: pH measurement inline (2-wire)	

1 Related documents

SSG 5415E — *Instrument installation — list of materials*
 SSG 5416E — *Process connections*
 SSG 5417E — *Installation details*
 SSG 5418E — *Instrument installation manual*

2 Installation principles according to SSG

SSG installation principles are covered by SSG 5402—SSG 5408:

- SSG 5402E — Analysis (A)
- SSG 5403E — Flow measurement (F)
- SSG 5404E — Level measurement (L)
- SSG 5405E — Pressure measurement (P)
- SSG 5406E — Temperature measurement (T)
- SSG 5407E — Valves (V)
- SSG 5408E — Other (Ö)