



## Pipe support elements – beam for supports and guides

Information within brackets ([...]) in this document refers to local regulations.

### Scope

This standard provides recommendations concerning beams used for pipe anchorages and guides made in accordance with [SSG 7005E](#).

### Changes since the previous edition

This edition differs from the previous edition in that:

- The standard has been updated in accordance with the current template for SSG standards.

### Contents

<b>1</b>	<b>Related documents</b>	1
<b>2</b>	<b>Designation</b>	1
2.1	Example	1
<b>3</b>	<b>Requirements</b>	1
3.1	General	1
3.1.1	Description	1
3.1.2	Material	1
3.1.3	Surface treatment	2
3.1.4	Manufacturing requirements	2
3.2	Dimensions	2
<b>4</b>	<b>References</b>	3

**1 Related documents** [SSG 7005E](#) – Anchorages and supports for pipelines – types.

**2 Designation** **Beams SSG 7030 - No - Length (L)**

**2.1 Example** **Beams SSG 7030 - 1 - 900**

### 3 Requirements

#### 3.1 General

The following conditions have been applied in the calculation of the strength values for beams. Safety factor 2 for the yield strength limit and 3.2 against the breaking limit.

##### 3.1.1 Description

Beam constituting a U-rod, flat bar and pipe clamps [SSG 7075E](#).

##### 3.1.2 Material

S235JRG2 in accordance with EN 10025.