



Date **2021-12-01**

Edition 6 Designation **TKR**

Page **1 (16)**

Piping – recommendations for the selection, classification and inspection of materials and

Scope

Information within brackets ([...]) in this document refers to local regulations.

This standard is intended for use as support for the creation of pipe systems. In the event of ambiguities, Swedish Work Environment Authority Documents [AFS 2016:1 and AFS 2017:3] apply. Recommendations for the choice of materials in pipe systems and associated components and their classification and inspection, are provided in the appendices based on the fluid codes and fluid data. For a summary of SSG PED pipe classes, see <u>SSG 7829E</u>.

In addition to the standard, there is an editable appendix that makes it possible to manage local plant-specific fluid codes. If necessary, the appendix can also be used to give SSG comments for future revisions of this standard. Then send the appendix to support@ssg.se.

Changes since the previous edition

This edition differs from the previous edition in that:

- Section 1 "Related documents" has been updated.
- Section 3 "Bases for classification" has been updated with information regarding hazardous work in a hazardous atmosphere.
- Section 6.4 "Flange guard" has been added.
- References has been updated.
- In Appendix 1: "Appendix "Fluid group A Additives"" fluid code A55 has been updated with hazard statement H290, H318 and pictogram code GHS05.
- In Appendix 2: "Fluid group B White water" the maximum operating temperature has been changed to 97 °C for fluid codes B57 and B58.
- In Appendix 3: "Fluid group C Condensate" fluid codes C26 and C42 have been updated with hazard statement, hazard category and pictogram. For fluid code C42, the remark "Fatal if inhaled" has been added. The remark "Observe H₂S levels" has been added for fluid code C43.
- In Appendix 7: "Fluid group G Gas" fluid codes G20, G27, G29,
 G30, G31, G50, G51 and G90 have been reviewed and updated.
- In Appendix 11: "Fluid group K Chemicals in the fluid phase and solid form" fluid codes K44, K60, K62, K90-K92 have been reviewed and updated. Fluid codes K100 (Formic acid) and K106 (Hydrogen peroxide, solution) have been added.
- In Appendix 12: "Fluid group L Lye, lye byproducts" fluid code
 L77 (Pitch [tall oil pitch]) has been clarified with a footnote for classification according to [AFS 2017:3].



Piping – recommendations for the selection, classification and inspection of materials and components

SSG 7650E

Date Edition Designation Page 2021-12-01 6 TKR 2 (16

- Information about used oil has been added to Appendix 15: "Fluid group O Oil, oil pollutants, lubricating oil, fossil fuels".
- Fluid code Vo1 (Exhaust, sulphate digester) in Appendix 22: –
 "Fluid group V Evaporation, evacuation" has been reviewed and updated with a new hazard statement.
- The operating temperatures for fluid code Wo5 and Wo6 in Appendix 23: "Fluid group W Water" have been updated. Fluid codes W61 (Water, softened warm) and W62 (Water, softened hot) have been added.
- In the editable appendix (Appendix X: "Deviant fluid codes") footnote ⁶⁾ has changed.



Piping – recommendations for the selection, classification and inspection of materials and components

SSG 7650E


Date E 2021-12-01

Edition **6**

Designation Page **3 (16**

Contents

1	Related documents	5	
2	Terms and definitions	5	
3	Bases for classification	5 6	
4	Fluid data/pressure classes	6	
5	Recommendations for the selection of materials		
	5.1 Corrosion	7	
	5.1.2 Chlorides and crack formation through stress corrosion (SCC) . 5.1.3 External corrosion	8	
	5.2 Cleaning agents	8	
	5.5 Titanium	8	
6	Recommendations for the selection of components		
·	6.1 Pipes and pipe fittings	. 10	
	6.3 Recommendations for the choice of gasket material6.4 Flange guard		
7	Recommendations for the design of insulation, marking and		
	mounting		
	7.2 Pipe markings		
	7.3 Pipe supports	. 11	
8	Manufacturing and classification		
	8.1 Pipelines > 0.5 bar		
^	·		
9	Inspection, plant inspection and classification		
	9.2 Plant inspection		
	9.3 Service life		
10	Materials and the scope of circumferential weld testing	. 14	
11	References	. 15	
Appendix 1: Appendix – "Fluid group A – Additives"			
Appendix 2: Fluid group B – White water			
Appendix 3: Fluid group C – Condensate			
Appendix 4: Fluid group D – Waste			
Appendix 6: Fluid group F – Fibre raw materials and parts thereof			
Appendix 7: Fluid group G – Gas			
Appendix 8: Fluid group H – Hydroxyl			
Appendix 11: Fluid group K – Chemicals in the fluid phase and solid form			
•	Annendix 12: Fluid group I – I ve Ive hyproducts		



SSG 7650E

Date 2021-12-01 Edition **6**

Designation Page **TKR** 4 (1)

Appendix 13: Fluid group M – Sludges and pigments

Appendix 15: Fluid group O – Oil, oil pollutants, lubricating oil, fossil

fuels

Appendix 16: Fluid group P - Pulp and fibre suspension

Appendix 19: Fluid group S - Steam

Appendix 22: Fluid group V - Evaporation, evacuation

Appendix 23: Fluid group W - Water

Appendix 30: Hazard pictograms and priority principles according to the

CLP ordinance

Appendix X: Deviant fluid codes